



# CITY OF MOUNTAIN VIEW

Finance and Administrative Services Department · Purchasing Division  
500 Castro Street · Post Office Box 7540 · Mountain View, California 94039-7540 · 650-903-6324 · FAX 650-968-5472

February 18, 2010

RE: PROPOSAL NO. R101340 ENERGY EFFICIENT LAMPS

## ADDENDUM NUMBER ONE

1. Revise Bid Specifications to include: All items must be UL listed.
2. Clarification to Item #2 - The correct voltage should be 120 volt. They need to be internally ballasted with aluminum heat sinks.
3. Clarification to Items 3, 4 & 5 - On the Induction lamp and generators, This is meant to be inclusive of all required components to make the lamps operate, i.e., heat sinks, required connectors that are sometimes sold as separate but necessary parts. The "any parts needed to retrofit" is not meant to mean parts required to retrofit the lamp to an existing fixture. It is solely related to any parts required to make the lamp operational.

This addendum must be signed below acknowledging receipt and returned with the completed proposal.

Sincerely,

Chris Hartje,  
Supervising Buyer

\_\_\_\_\_  
Signature of Officer  
signifying receipt and understanding of  
this addendum

\_\_\_\_\_  
Date